# $C \in \cap \cap O^{\circ}$

### General Product information 🥵 🖤


This product is suitable for indoor dry and damp locations only.

This product is to be installed to a 4" square junction box with a 3" round plaster ring or an octagon junction box.

Bulb and Dimmability Notes:

GU-24 Version: The ability to dim the fixture will depend on the type of bulb selected. The GU-24 version of this fixture accepts GU-24 based lamps (not included). Ensure that the lamps do not exceed the maximum rated wattage listed on socket.

LED Version: Fixture can be dimmed with TRIAC, ELV, or 0-10V dimming at 120VAC input. For 240 or 277VAC input, fixture is only dimmable with 0-10V dimming. Wiring details are outlined on second page of instructions.



## CAUTION - RISK OF FIRE


This product requires installation by a qualified electrician. Before installing be sure to read all instructions and TURN POWER OFF TO THE JUNCTION BOX

#### - All Models


Adjusting the Fixture Height

Place the shiny side of the top diffuser over the cross assembly. Measure the desired height (H) that you want the fixture to hang below the ceiling.

2 Adjust the length of the suspension cables to roughly the desired length by pushing them into the side-exit cable grippers located on top of the cross assembly. Final adjustments can be made after the fixture is mounted.



– GU-24 Model Only –




Mounting the Fixture


3 Fasten the universal crossbar to the ceiling junction box using the included #8-32 x 3/4" machine screws.

Pull line voltage wires through crossbar. Feed the clear power cord coming from the cross assembly through the top diffuser and then through the strain relief hole in the canopy and make connections between line voltage wires and power cord.

5 After electrical connections have been made, place wire connections and excess wire into the junction box.

6 Fasten the canopy to the universal crossbar using the included #8-32 x 1.75" screws.





CERNOGROUP.COM