


General Product Information


This product is suitable for indoor dry and damp locations only.

This product is to be installed to a standard 4" junction box with 3" round plaster ring or an octagon junction box.

Fixture can be dimmed with TRIAC, ELV, or 0-10V dimming at 120VAC input. For 240 or 277 VAC input, fixture is only dimmable with 0-10V dimming.







CAUTION - RISK OF FIRE

This product requires installation by a qualified electrician. Before installing be sure to read all instructions and TURN POWER OFF TO THE JUNCTION BOX

- Measure the desired height (H) that you want the fixture to hang below the ceiling.
- Thread the cable through the canopy thumb nut, low profile canopy, crossbar and strain relief fitting.
- 3 Tighten the set screw on the strain relief fitting onto cable at desired height (H) using a small flathead screw driver. As an added safety measure, tie a knot in the cable above the strain relief.
- Make electrical connections as shown in the image to the left using the supplied wire nuts.

CRITICAL NOTE: If 0-10V dimming control is to be used, connect purple and gray driver leads to 0-10V dimmer. Otherwise, the tinned ends of these leads should be snipped off and the leads should be capped individually such that they remain isolated from one another.

- (5) Attach the crossbar assembly to the junction box using the supplied #8-32 screws.
- After electrical connections have been made, place wire connections, driver, and excess wire into the junction box.
- Slide the canopy up the cable and secure it by screwing the thumb nut onto the crossbar assembly.



 CERNOGROUP.COM
 T_949.715.1534
 22892 GLENWOOD DR, ALISO VIEJO, CA 92656
 COPYRIGHT 2023 CERNO LLC
 ISSUE DATE 08/21/2023